

**BY ORDER OF THE COMMANDER
AIR EDUCATION AND TRAINING
COMMAND**

**AFOSH STANDARD 91-56
AIR EDUCATION AND TRAINING COMMAND**



Supplement 1

6 MAY 1999

Safety

FIRE PROTECTION AND PREVENTION

“HOLDOVER”

“The basic publication has changed; impact on supplemental information is under review by the OPR. Users should follow supplemental information that remains unaffected.”

COMPLIANCE WITH THIS PUBLICATION IS MANDATORY

NOTICE: This publication is available digitally on the HQ AETC Publishing WWW site at <http://www.aetc.randolph.af.mil/im>. If you lack access, contact your base publishing manager.

OPR: HQ AETC/CEOX (Mr C. Byrd)
Supersedes AFOSH Std 127-56/AETC Sup 1,
15 December 1994

Certified by: HQ AETC/CEO (Col R. Turner)
Pages: 1
Distribution: F

AFOSH Standard 91-56, 1 July 1998, is supplemented as follows:

2.4.9. Use AETC Form 750, **Fire Extinguisher Hydrostatic Test Record**, to record hydrostatic test date, test pressure, and name of person or agency conducting test.

2.11. (Added)(AETC) Forms Prescribed. This supplement prescribes AETC Form 750.

DAVID M. CANNON, Colonel, USAF
The Civil Engineer